



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8801CP0060

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Geberit International AG Schachenstrasse 77, CH-8645 Rapperswil-Jona
Distributor <i>Vertreiber</i>	Geberit Vertriebs GmbH Theuerbachstraße 1, D-88630 Pfullendorf
Product Category <i>Produktart</i>	Installation systems with special pipes (PN 10): Drinking water installation systems (8801)
Product description <i>Produktbezeichnung</i>	drinking water installation systems consisting of multilayer pipe PE-RT/Al/PE-RT and compression connectors made of plastic PVDF or PPSU (type M-KV) respectively metal (type M-MV), unpressed leaky
Model <i>Modell</i>	Mepla-System
Test reports <i>Prüfberichte</i>	Laboratory control test: RA1830.229488.23 from 11.07.2023 (SKZ) Type testing: B426/12.14+B426/12.15 from 22.12.2014 (IMA) Type testing: B426/12.10A from 20.07.2017 (IMA) Type testing: B426/12.15A from 20.07.2017 (IMA) Type testing: V233/22.2 from 13.11.2023 (IMA)
Test basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW W 542 (01.08.2009) UBA BWGL-Metalle (11.01.2023) UBA ELASTOM (16.03.2016) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	18.02.2029 / 23-0828-WNV

70028 GI A DE

27.11.2023 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

J. A. W. Z.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Mepla-System	Diameter: 16,0 x 2,25 mm	
Mepla-System	Diameter: 20,0 x 2,50 mm	
Mepla-System	Diameter: 26,0 x 3,00 mm	
Mepla-System	Diameter: 32,0 x 3,00 mm	
Mepla-System	Diameter: 40,0 x 3,50 mm	
Mepla-System	Diameter: 50,0 x 4,00 mm	
Mepla-System	Diameter: 63,0 x 4,50 mm	
Mepla-System	Diameter: 75,0 x 4,70 mm	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DW-5253BQ0461	Sealing material for drinking water installations	TIMO-70/TIMO-70	Tecnogomma International S.p.A.
DW-5253BR0355	Sealing material for drinking water installations	LOPI 70/LOPI 70	Lopigom S.p.A.
NW-5253BT0306	Sealing material for drinking water installations	TIMO 3-70/TIMO 3-70	Tecnogomma International S.p.A.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

only to use with multilayer pipe: PE-RT/Al/PE-RT, in coils:

16,0 x 2,25 mm (Al: 0,37 mm),

20,0 x 2,50 mm (Al: 0,44 mm),

26,0 x 3,00 mm (Al: 0,65 mm),

manufacturer: Geberit International AG, CH-Givisiez

only to use with multilayer pipe: PE-RT/Al/PE-RT, in straight pipes:

16,0 x 2,25 mm (Al: 0,47 mm),

20,0 x 2,50 mm (Al: 0,57 mm),

26,0 x 3,00 mm (Al: 0,65 mm),

32,0 x 3,00 mm (Al: 0,75 mm),

40,0 x 3,50 mm (Al: 0,95 mm),

50,0 x 4,00 mm (Al: 0,95 mm),

63,0 x 4,50 mm (Al: 0,95 mm),

75,0 x 4,70 mm (Al: 1,19 mm),

manufacturer: Geberit International AG, CH-Givisiez

only to use with compression connectors:

type M-MV, Beulco GmbH & Co. KG, D-Attendorn and Bender Armaturen GmbH & Co KG, D-Lennestadt

only to use with compression connectors:

type M-KV, Geberit International AG, CH-Jona

